

## **SPECIFICATION CLAUSE**

### **Airstract Terminals**

*Provide ventilation by means of Passivent Airstract ventilation terminals supplied by Passivent, North Frith Oasts, Ashes Lane, Hadlow, Kent TN11 9QU. Telephone: 01732 850770. Fax: 01732 850949. Email: [projects@passivent.com](mailto:projects@passivent.com).*

*Airstract terminals to have been appraised under BS EN ISO 9001. Terminal cladding and louvres manufactured from fireretardant high-impact ABS and connected to a base unit of marine grade plywood from renewable forests. Resistant to wind loads up to 51m/s, fitted with 4mm insect screen.*

*Double-bank louvres to achieve 100% rain rejection, class A effectiveness. Terminal width .....mm, length .....mm, ventilation area .....mm<sup>2</sup>, roof pitch ..... Colour and texture ..... to match roof covering of ..... tiles/slates/sheeting\*. Multiple outlets: ..... [give details] iAT fan installed in terminal . \* Motorised base damper with internal cover grille. \* Installed by an approved MasterCare installer. \**

\*Delete as applicable.