

SPECIFICATION CLAUSE

Airscoop Terminals

Provide ventilation by means of Passivent Basic/DAD/RAD Airscoop roof-mounted ventilation terminals with automatic damper control, supplied by Passivent, North Frith Oasts, Ashes Lane, Hadlow, Kent TN11 9QU. Telephone: 01732 850770. Fax: 01732 850949. Email: projects@passivent.com.*

Terminals to have been appraised under BS EN ISO 9001. Terminals of high-impact ABS with all exposed surfaces treated with UV-stable polymeric resin, base of marine grade plywood. Weather performance tested to BS EN 13030 'Performance testing of louvres subjected to simulated rain': double-bank louvres Class A 100% at 0.00m/s, Class A 100% at 0.50m/s.

*Thermal insulation U-value 1.6W/m²K when basic dampers are closed, resistant to continuous wind loads at 51m/s, AA classification tested to BS 476: Part 3, 4mm insect screen. Colour and texture to RAL / BS colour or to match roof covering. Installed by an approved MasterCare installer.**

*Delete as applicable.